

DAP-PL-4077.00

(German Accreditation Council)

Test laboratory accredited by DAP GmbH according to DIN EN ISO/IEC 17025.
The accreditation applies to the test methods shown on the certificate



Business Division III – Fire Protection for Buildings

Head of Business Division: Dr.-Ing. Peter Nause

Working Group 3.2 – Fire Characteristics of Components

Expert Opinion

GSIII/08-103

20.01.2009 First Copy

Subject: Expert opinion on the fire characteristics of reinforced-concrete walls in combination with KE double-wall transport anchors with respect to fire resistance for 90 minutes

Client: H-Bau Technik GmbH

Am Güterbahnhof

D-79771 Klettgau

Date of order: 04.12.2008

Project manager: Dr. Nause

This expert opinion comprises 6 pages.

This report must only be copied in unabbreviated form. Publication – either in part or in full – requires the prior written consent of M F P A Leipzig GmbH. The only legally binding form is the printed version with the original stamp and the original signature of the authorized signatory or signatories.

M F P A Leipzig GmbH (Gesellschaft für Materialforschung und Prüfungsanstalt für das Bauwesen Leipzig mbH [Materials Research and Test Institute for the Construction Industry, Leipzig GmbH])

1 Order/reason for order

With your e-mail of 04.12.2008, you commissioned MFPA Leipzig to draw up an expert opinion on the fire characteristics of load bearing or non load bearing reinforced-concrete walls for the construction of closed spaces when used in combination with permanently embedded KE double-wall transport anchors, with respect to fire resistance for 90 minutes.

This expert opinion is made necessary by the fact that the planned design of reinforced-concrete wall structures combined with KE double-wall transport anchors is not covered directly by DIN 4102-4 or any other general tests used in the regulation of the construction industry.

2 Basis of this expert opinion and related documents

This expert opinion is based, on the one hand, on the requirements of construction-industry regulations, which require classification of reinforced-concrete wall structures combined with KE double-wall transport anchors to form a fire-resistant structure and, on the other hand, on the following additional information and documents:

- DIN 4102-2,

- DIN 4102-4,

- Technical data sheets supplied by H-Bau Technik GmbH, relating to KE double-wall transport anchors.


This assessment draws not only on the above materials but also on the extensive experience of MFPA Leipzig GmbH in testing the fire characteristics of reinforced-concrete structures.

3 Description of the structure

KE double-wall transport anchors are used for righting and transporting prefabricated reinforced-concrete double walls both at the prefabrication plant and on construction sites. They are composed of concrete reinforcing steel and a compression member made of wood and, after concreting, they remain in the continuous solid wall, which is at least 180 mm thick. According to the information you provided, the minimum outside concrete coverage of the round steel bar of the transport anchor (minimum bar diameter for KE I = 10 mm) is 20 mm, giving a minimum concrete coverage of the wooden compression member embedded in the concrete of about 25 mm.

Figure 1 below shows the design of the KE double-wall transport anchor in schematic form.

Figure 1: Design of KE double-wall transport anchors in schematic form



No further description of the KE double-wall transport anchor will be given, attention being drawn to the information in the following figure 2 since it is shown in sufficient detail there.

Figure 2: Dimensions of the KE double-wall transport anchor

Type	KE I*		KE III		KE IV*	
	Dimensions [mm]		Dimensions [mm]		Dimensions [mm]	
	w	l	w	l	w	l
120	120	370	120	515	120	750
130	130	370	130	515	130	750
140	140	370	140	515	140	750
150	150	370	150	515	150	750
160	160	370	160	515	160	750
170	170	370	170	515	170	750
180	180	405	180	565	180	800
190	190	405	190	565	190	800
200	200	405	200	565	200	800
210	210	405	210	565	210	800
220	220	405	220	565	220	800
230	230	405	230	565	230	800

Type	KE I*		KE III		KE IV*	
	Dimensions [mm]		Dimensions [mm]		Dimensions [mm]	
	w	l	w	l	w	l
240	240	405	240	565	240	800
250	250	440	250	615	250	850
260	260	440	260	615	260	850
270	270	440	270	615	270	850
280	280	440	280	615	280	850
290	290	440	290	615	290	850
300	300	440	300	615	300	850
310	310	460	310	645	310	880
320	320	460	320	645	320	880
330	330	460	330	645	330	880
340	340	460	340	645	340	880
350	350	460	350	645	350	880

Concrete covering on the outside c_{nom} [mm]	Concrete covering on the inside c_{innen} [mm]	Minimum shuttering thickness min s^* [mm]
20	≥ 10 mm ≥ 20 mm ⁴⁾	50
25		55
30		60

⁴⁾ Only applies to KE IV transport anchors with 200 mm widths per side in the anchor region.

4 Expert opinion

The solid reinforced-concrete walls described in section 3, combined with KE double-wall transport anchors, were assessed with respect to fire protection on the basis of DIN 4102-4 and extensive experience in the testing of such structures, to determine whether they meet the protection targets required by building regulations (maintenance of load-bearing capacity, sealing of enclosed space and insulation) when subjected to fire for 90 minutes on one side in accordance with the standard temperature-time curve specified in DIN 4102-4.

On condition that minimum wall thicknesses of 180 mm and the specified 25-mm minimum concrete coverage of the wooden compression member are maintained, it is sufficiently certain that there need be no reservations about assigning the reinforced-concrete walls, combined with the KE double-wall transport anchors that remain throughout their cross section, to fire resistance class F90 since, on the one hand, the minimum wall thicknesses specified in DIN 4102-4 are significantly exceeded and, on the other hand, ignition and, furthermore, burning through in this partial area within 90 minutes can be excluded.

It can therefore be stated with sufficient certainty that the fire protection targets specified by DIN 4102-2: 09-1977 will be achieved by reinforced-concrete walls with the specified minimum thickness of 180 mm combined with the permanently embedded KE double-wall transport anchors, as regards maintenance of

- sealing of the enclosed space,
- insulation and
- stability

when subjected to fire for 90 minutes on one side in accordance with the standard temperature-time curve given in DIN 4102-2.